


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. PHC Thangaon /133/2025

Date: 23 June 2025

It is certified that an inspection team headed by Dr. Sarvesh R. Arote  
Medical officer (A) (Name of Officers with designation) from Primary Health Centre, Thangum  
(Name of Department/ Office)  
inspected Sacred Heart Public School, Dhondvir Nagar, Sinnar, Tal. Sinnar, Dist. Nashik  
(Name and address of the School) on 23 June 2025 (date of inspection), checked the  
water test report submitted by the school and found that the school has potable drinking  
water for students and staff of the institution and is having provision for running water  
in the toilets and maintaining hygienic sanitation condition in the school building & the  
campus as per norms prescribed by the Central/State/UT. Govt.

The above certificate is valid for a period of one year



Signature with Seal: Dr. Sarvesh R. Arote

Name : Dr. Sarvesh R. Arote

Designation : Medical officer (Grade A)

To

The Principal,

Sacred Heart Public School,

Dhondvir Nagar, Sinnar,

Tal. Sinnar, Dist. Nashik.

Dr. Sarvesh R. Arote

**MANAGER**  
SACRED HEART PUBLIC SCHOOL  
DHONDVIRNAGAR, SINNAR  
DIST. NASHIK-422103.

Dr. Sarvesh R. Arote

**PRINCIPAL**  
SACRED HEART PUBLIC SCHOOL  
DHONDVIR NAGAR, SINNAR,  
DIST. NASHIK-422103.



**Maharashtra Government**  
**DISTRICT PUBLIC HEALTH LABORATORY, NASHIK**

Office Phone No.:- 0253 – 2570613

Email Id:- dphlnasik@gmail.com

**Office:- Junior Scientific Officer District Public Health, Laboratory,  
Civil Hospital Campus, Trimbak Road, Nashik - 422 001.**

NO. DPHL/NSK/WC/ W-203/ 2350 /2025

Date:- 09/06/2025

Health Services

**REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES**

Date of Collection- -----	Date of receipt- 23/05/2025	Date of Examination-23/05/2025 & onwards
Letter No:--NIL		Dated: 23/05/2025

**Analytical results in mg/litre (except pH& turbidity)**

Sr. No.	Name of Test	Results	BIS Specification 10500:2012 Normal values	
			Acceptable limits	Permissible limits
	Source	Open Well (RO filter)	-----	-----
01	Physical appearance	Clear, Colorless	-----	-----
02	Odor	Agreeable	Agreeable	Agreeable
03	pH	6.9	6.5 to 8.5	No relaxation
04	Turbidity (NTU)	0.10	1.0	5.0
05	Chlorides	14	250	1000
06	Total Hardness	56	200	600
07	Total alkalinity	30	200	600
08	Total dissolved solids	100	500	2000
09	Fluoride	0.03	1.0	1.5
10	Iron	0.04	1.0	No relaxation
11	Nitrates	0.82	45	No relaxation
12	Permanent hardness	26	-----	-----

**Note:** (A) It is presumed that the representative sample/s from the stock is/are sent for analysis.  
(B) This report is restricted to the sample/s submitted in the laboratory. (C) This sample/s is/are not collected by this laboratory.

**Remarks:** Sample no. 01 is chemically fit for drinking purpose on the basis of analyzed parameters only. However, this water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining their bacteriological quality frequently or regularly.

Forwarded with compliments to:

Jilesh PL,  
Principal,  
Sacred Heart Public School,  
Dhondvir nagar,  
Tal. Sinnar,  
Dist. Nashik

**Junior Scientific Officer**  
District Public Health Laboratory,  
Nashik.

R.No: 5147090; Rs. 600; Dt: 23/05/2025

**MANAGER**  
SACRED HEART PUBLIC SCHOOL  
DHONDVIRNAGAR, SINNAR  
DIST. NASHIK-422103.

-----END OF REPORT-----

**PRINCIPAL**  
SACRED HEART PUBLIC SCHOOL  
DHONDVIR NAGAR, SINNAR,  
DIST. NASHIK-422103.